



**TREZOR TEST s. r. o.**  
**Na Vršku 67, 250 67 Klecany, Czech Republic**

**CERTIFICATION BODY No. 3025**  
**ACCREDITED BY**  
**THE CZECH ACCREDITATION INSTITUTE**

# **CERTIFICATE OF CONFORMITY**

**Registration number: TT - 96/2022**

**for**

**ČETRТА POT, d.o.o.**  
**Planina 3, SI – 4000 Kranj, Slovenia**

**PRODUCT:** Access Control System KADRIS 4  
with VT-500 controller  
in the report, see Annex No. 1  
Producer: ČETRТА POT, d.o.o.  
Planina 3, SI – 4000 Kranj, Slovenia  
CZ-CPA 27.90.11

**CLASSIFICATION:** The product is in accordance with the certification schema CS TT 1a/2020 (based on scheme 1a EN ISO/IEC 17067:2013, based on testing)

and in conformity with requirements of

EN 60839-11-1:2013

## **Security Grade 4, Environmental Class II**

The certificate is issued on the basis of the Certification report No. CE 9/2022 within the accreditation according to the Certificate No. 22/2022 of 14th February 2022 issued by the Czech Accreditation Institute.

Chairman of the Certification board  
CO No. 3025  
Ing. Ladislav Polák

Deputy chairman of the Certification board  
CO No. 3025  
Ing. Daniela ČÍŽKOVÁ

Date of publication: 10.03.2022  
Certification date: 10.03.2022  
Certification expiration date: 10.03.2025



This Certificate of Conformity may be used and reproduced in unchanged form only.

Certification body No. 3025  
Company TREZOR TEST s.r.o.  
Na Vršku 67, 250 67 Klecany

Appendix 1 is an integral part of  
the certificate no. TT - 96/2022  
Page: 1 / 1

#### Access Control System KADRIS 4 with VT-500 controller

1) The VT-500 access control unit, including the backup power supply, can control up to 4 passages in the primary security configuration (one-way or two-way); or up to 16 passages (one-way) in ancillary security arrangement, SN: 02466, environment class II,

- battery 6 x A123 (Li-Ion Phosphate); 5 Ah, no v. No., Manufacturer LithiumWerks

2) CM03/TP - contactless card reader, SN: 03514, environment class II,

3) CM03/TP/SF - contactless card reader with keyboard, SN: 01001, 01002, environment class II,

4) CMX3 - contactless card reader, SN: 00505, environment class II,

SW KADRIS 4 - SW for management and monitoring of the VT-500 access control system,

Identification cards 17 pcs